



Third West Air Monitor Result Shepherd, Michael

to:

Joyce Ackerman, 'Craig Barnitz (cbamitz@utah.gov)'
02/01/2012 03:23 PM
Hide Details
From: "Shepherd, Michael" <Michael.Shepherd@PacifiCorp.com>

To: Joyce Ackerman/R8/USEPA/US@EPA, "'Craig Barnitz (cbamitz@utah.gov)"

<cbamitz@utah.gov>

2 Attachments





228714-1.pdf 228782-1.pdf

Joyce & Craig,

We had positive hits on January 27, 2012 and January 30, 2012. All were chrysotile, see the attached. Please let me know if you have any questions or concerns.

Thanks,

Mike Shepherd
Project Manager
Rocky Mountain Power - Major Projects
801.220.4584 Office
801.631.1310 Cell
801.220.2797 Fax
michael.shepherd@pacificorp.com



January 31, 2012

Laboratory Code:

RES

Subcontract Number:

NA

Laboratory Report: Project # / P.O. #

RES 228714-1 None Given

Project Description:

3rd West Sub - RMP

Eldon Romney R & R Environmental 47 West 9000 South #2 Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental. Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed in general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 228714-1 is the job number assigned to this study. This report is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described in this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely,

Jeanne Spencer Orr

President

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:

RES 228714-1

Client:

R & R Environmental

Client Project Number / P.O.: None Given

Client Project Description:

3rd West Sub - RMP

Date Samples Received:

January 30, 2012

Analysis Type:

TEM, AHERA

Turnaround:

24 Hour

Date Samples Analyzed:

January 31, 2012

Client	Lab		Area	Air	Number of	Analytical	Asbestos	Filter
ID Number	ID N	umber	Analyzed	Volume Sampled	Asbestos Structures Detected	Sensitivity	Concentration	Loading
	•		(mm²)	(L)		(s/cc)	(s/cc)	(s/mm²)
3W-012712 SW	EM	857443	0.0900	900	4	0.0048	0.0190	44.4
3W-012712 NW	EM	857444	0.0900	898	ND	0.0048	BAS	BAS
3W-012712 NE	EM	857445	0.0900	898	ND	0.0048	BAS	BAS
3W-012712 SE	EM	857446	0.0900	896	ND	0.0048	BAS	BAS

NA = Not Analyzed

ND = None Detected

BAS = Below Analytical Sensitivity

Average Grid Opening in mm² = 0.010

Filter Material = Mixed Cellulose Ester

Filter Diameter = 25 mm

Effective Filter Area = 385 sq mm

DATA QA

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE II. SUMMARY OF ANALYTICAL DATA

RES Job Number:

RES 228714-1

Client:

R & R Environmental

Client Project Number / P.O.: None Given

Client Project Description:

3rd West Sub - RMP

Date Samples Received:

January 30, 2012

Analysis Type:

TEM, AHERA

Turnaround:

24 Hour

Date Samples Analyzed:

January 31, 2012

Client ID Number	Lab ID N	umber	Asbestos Mineral	Ast	estos Str	uctu re Typ	pes*	Structures >5 Microns in Length	**Excluded Structures	Asbestos Structures for
			•	Fibers	Bundles	Clusters	Matrices			Concentration
3W-012712 SW	EM	857443	Chrysotile	2	0	2	0	0	0	4
3W-012712 NW	EM	857444	ND	0	0	0	0	0	Ó	0
3W-012712 NE	EM	857445	ND	0	0	0	0	0	0	0
3W-012712 SE	EM	857446	ND	0	0	0	0	0	0	0

^{*}See Analytical Procedure for definitions

^{**}C = Excluded from total due to lack of confirmation

^{**}L = Excluded from total for length less than 0.5 micron (AHERA only)

^{**}A = Excluded from total due to i ncorrect aspect ratio

ND = None Detected

Due Date: 1-31-12 Due Time: 945-

S801 Logen St Oenver, CO 902te • Pic 303 804-1886 • Fex 303 477-4275 • Toll Free :866 RESI-ENV

Pager : 303-500-2098

Page 1 of 1

	INVOICE TO: (IF	DIF	FERE	NT)										CONTA	CT				ON:				
Company: RER Environmental	Company:					Co	tact:	Qu	re	lo	560	ile.					Contact						
Address: 47 W 90005 #2	Address:					Pho	ns:								,		Phone:						
Sunda W. 821070						Fax											Pax:						
						Cel	Vpager	· 80	21	54	1-1	034	<u> </u>				Cell/peg	jsr:					
Project Number an #or P.O. #:						_ Fir	s) Dati			-													
Project Description/Location: 3th West Sub-RMP							de	we	<u>u</u>	M	<u>~~</u>	10.	Copes			_							
ASBESTOS LABORATORY HOURS: Weehdays: 7am • 7pin		T	: :		R	REQU	EST	ED/	ANA	\LY!	SIS	: :	. :	7	V	ALI	D M	ATRI)	x co	DES	LAI	BNOTE	s:
PLM / PCM / TEM)RUSH (Same Day) K PRIORITY (Next Day)	STANDARO			T				\Box	T	П	Т	\sqcap	TT	7.	Alı	r = #	·		Ві	ılk = B		1	
(Rush PCM = 2hr, TEM = 6hr.)]				1	H			Н		$ \cdot $			Dus	st =	D		Pa	int = P	u		
CHEMISTRY LABORATORY HOURS: Weekdays: Sam - 5pm]]]]]]]]]		So	il = :	5		Wij	pe = W	-	(3)	(<u>2</u> _
Metal(s) / Dust RUSH 24 hr3-5 Day		1	7	1 1	1	- {	1			1		} }	1 1		Swal	b = \$	SW	T	F	= Food			
RCRA 8 / Metals & WeldingRUSH 5 day10 day	**Prior notification la retulted for RUSH	<u>ਵ</u>	Quant,	1 (li	l _s			1	됳	ļ	1	s	Orlnk	ing \	Nal a	r = D'	w w	aste V	Vater = WW			
Fume Scan / ICLP	turnarounds.**	18	Page .			Scan				1			8 2				0	= Othe	er		L		
Organics 24 hr 3 day 5 Day		Point Count	SC P	1 1		Metals			İ	Quantif	8	اء	NOTES	**A	STM	E17:	92 app	roved	wipe n	nedia only**	L		
MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pm			- 02						1	8	ខ្លួ	ig c	Mold: +f-, identification, Qui	}	- 1						<u> </u>		
	3-5 Day	Long report,	7402, ISO-Indi	7400A, 7400B, OSHA		METALS - Analyte(s) RCRA 8, TCLP, Webding Fume,				4	2 5	看屋	§ 6		- {	- {			[<u> </u>		
Salmonella, Listeria, E.call, APC, Y & M48 Hr3-5 Day		g	= ·	ğ	Respirable	اقق ا		.			o de	o de la constant	2 8		1	-			Ì		<u> </u>		
	48 Hr3 Day5 Day		evel	8	\$	§ §	Īī					8 0	£ 3	1		Ì	1		1				
Tumerpund Ilmes satablish a laboratory priority, subject to laboratory volume and er apply for afterbours, weakends and holidays.	a not guaranteod. Additional faas	Short report,	RA, Level Micro-vac,	7.	œ	\$.	ÆT	Salmonetta: +/-	1	<u>اق</u>	६ दे	÷ 5	ŢĘ	Ę	-	- }	. }		}		- 33		
<u> </u>		ह	AHERA, 18nt, Mic	ğ	- Total,	₹ ਹ	8	18 S	*	g :	Ė	ig =	÷ Ξ	₹	_	睌	9		- 1				17.
Special Instructions:		8	4 8		; l	ა დ	욁	E 8	Ē	g i	Coliforns	S.aurer	ğ 🖺	ا ۾	2	ق	賣	Date	e	Time		n ber (Lat	
		Ę	Semi-	25 20 20	DUST	¥ ¥	ORGANICS - METH	இற		3				Sample Volume	ור) / הפס	Matrix Code	# Containers	Collec	ted	Collected	1.5	ise Only)	•
Client sample ID number (Sample ID's must be uniqua)		٦		12	5	3 ×	Ö	_	MIC	CROS	HOLO	XY	- 3		_	-		mm/dd		hh/mm a/p			
1 3W 012712 SW		\sqcup	K					\perp	<u> </u>	Н	4	Ц.		90	_	+	10	1127	112		SS	744	3
2 3W -012712 NW	and the management of					: <u>15.4</u>			Ĺ	ŀ		Ŀ		1891	۱ م	$oxed{1}$				11	111		14
3 3W 012712 NE														89.8]			_	7
4 52W-012712 SE			1].			1	Π		1	.].		891	0			7			V	7 4	6
5					_			\top	Ti	T	1		 	1	7		7		_				-
6					1			+	+-	H	╁	-	+	-	+	+	+						
	_ 	\vdash	<u> </u>	╁┼	-+	<u> </u>	-		H	H	+-	+	 	-{	+	+	-		 -{			· ·	
7		┞╌┤		\vdash	_			+	+-	-			 	┿	-	\dashv	+		\dashv		-		
8				-	-4			- -	\downarrow	<u> </u>	_			1	1	4						<u>-</u>	<u> </u>
9	· · · · · · · · · · · · · · · · · · ·							1	$oldsymbol{\perp}$							4			_				
10				L				. [1:		1 1	1.		-				.	·		٠.
Number of samples received: (Addition	al samples stiall be listed on	attac	lied lo	ng for	rm.)																		
NOTE: REI will enelyze incoming samples bread upon information received and will not be re	sponsiete for arrors or omissions in c	alculati	ens tes	ulting fr	rom the	a inaocu	racy o	f origin	nel da	ola. By	s ig ni	no dien	I/Cxmpany	sprasents	tiva a	graa	e that s	ubmiss	ion of t	ha lollowing sar	nples for req	uested	
analysis es indicated on this Chain et Custody shall constitute an analytical services agreeme	nt with payment terms of NET 30 day	s, tallu	re to ∞	TON-W	th pay	ment te	ms m	ay res	utt in	a 1.59	6 mor	thly inte	erest surche	rge.									
Relinquished By: Lutur James				Date	/Time	e: It	24	HZ						ls	amp	le C	ondit	tion:	0	n Ice S	ealed	Intact	
Laboratory Use Only	/ma									\leq									Ye	s/No Ye	s/No	-Yeş ITI	0
Received By: Date	offine: (3412	۾_	/₽	4	2	Carrier	I	عع	20	9	2	<u></u>		L	,							1	
Results: Contact Con (Phone Email Fax Date 3	Time 10 40 a Initi	als.∦	<u> </u>	ntact				Phon	e €	mari	Eoo			Date	<	<u> </u>	<u>اک</u>		Time	1744	Initia	s 5	<u> </u>
Contact Phona Email Fax Date	Time loili	ais/	Co	ntact				Phon	a E	mail	Fax			Date					Time		Initial	s 🕖	
	14	7	7	2	1	C. 2	2	3	2		5	~						_			•	_	
	Joseph.	7-	2 0 11		•		•	_		_		-											

Attachment I

Key to Count Sheets Count Sheets Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type	Structure Types
A = Amosite An = Anthophyllite C = Chrysotile Cr = Crocidolite	F = Fiber B = Bundle C = Cluster M = Matrix
T = Tremolite	

ND = no structures detected

M = other structure associated with a matrix

NAM = Non Asbestos Mineral


XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr Nathan DelHierro Angela Heitger Jonathan Bernard Paul D. LoScalzo Mark Steiner Norberto Zimbleman Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Reservoirs Environmental, inc.
TEM Asbestos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX N S
Voltage (KV)	100 KV
Magnification	20KX) 10KX
Grid opening area (mm2)	0.01
Scale: 1L o	0.2S um
Scale: 1D=	0.056 um
Primaty filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Tyoe	

. I EM ASDESIUS SIN	actare count .
Client:	Rok
Sample Type (A≖Air, D≕Dust):	A
Air volume (L) or dust area (cm2)	900
Date received by lab	1/30/12
Lab Job Number:	228714
Lab Sample Number:	857443

Lab Sample Number:	1 - 3. 7 - 7 - 7
F-Factor Calculation (Indirect Pre	eps Only):
Fraction of primary filter used	
Total Resuspenaion Volume (ml)	
Volume Applied to secondary filter (ml)	

Analyzed by	JB
Analysis date	1/31/12
Method (D=Oirect, I=Indirect,	1 1 1
IA=Indirect, ashed)	
Counting rules	0.1
(ISO, AHERA, ASTM)	
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure	No. of St	mctures	Dime	nsions	identification	Mineral Class				1 = y	es, blanic	= no
Grid	Grid Opening	Туре	Primary	Total	Lenoth	Width	identification	Amphibole	. с	NAM	· Skatch/Comments	Sketch	Photo	EDS
A	HZ-!	ND							,					
	62-1	F		١	5		CD.		/					
	F2-1	ND.										<u>.</u>		
	E26	MD		:	(ns A	50/	ntunt-	3.5	2 deb	n's			
	F26.	M		*:	,	no B	90%.	nbont :	3-5	% del	n's			
3	K4-1	C		. 2	4	2	0		/		0 *			
		\mathcal{C}		3	3		ρ		V		A			
		7):		4	5	(Ċ.		~		/			
	H41	MD							•					
	64-1	NO.		·										

Reservoirs Environmental, inc. TEM Asbestos Structure Count

LAB NAME	REI	Lab Job Number:	2287	H	Analyzed by:		TV	5	
	 · · -	 Lab Sample Number	8574	15	Analysis Date:		134	12	
	 				 		<i> </i>	<u>-</u>	

					·			 			· · · · · · · · · · · · · · · · · · ·	/		
Grid	Grid	Structure	- No. of St	ructures	Dime	nsions	Identification	Mir	neral Clas	s		1 = yes, blani		= no
0	Opening	Туре	Primary	Total	Length	Widfh		Amphibole	С	NAM.	Sketch/Comments	Sketch	Photo	EDS
13	F4-1	ND			·									:
														•
							1B 1/31/	2					·	
						/								
. 						·								
								·				• .		
<u>-</u>						·	•							
								,						
									•				•	
:						·								
													1 .	· ·
	·						,				,			
· · · · · · · · · · · · · · · · · · ·		,						•						:

Reservoirs Environmental, Inc. TEM Asbestos Structure Count

Laboratory name:	REI_
Instrument	JEOL 100 CX (N' S
Voitage (KV)	100 KV
Magnification	20KX 10KX
Grid opening area (mm2)	0.01
Scale: 1L=	0.28 um
Scale: 1D =	0.056 um
Primaty filter area (mrit2)	385
Secondary Filter Area (mm2)	
QA Tyoe	

Client :	Rok
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	898
Date received by lab	1/30/12
Lab Job Number:	228714
Lab Sample Number:	857444

F-Factor Calculation (Indirect Pre	ps Only):
Fraction of primary fitter used	
Total Resuspension Volume (mi)	
Volume Applied to secondary filter (m0)	

Analyzed by	JB
Analysis date	1/3/1/2
Method (D≂Direct, l≈Indirect, tA=indirect, ashed)	7
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

1		· ·		- 				r		:	`				
ı	Grid	Grid Opening	Structure	No. of St	ructures		nsions	Identification	Mineral Ctass				1 = y	es, biank	= no
			Туре	Primary	Total	Length	Width	•	Amphibote	С	NÀM	Sketch/Comments	Sketch	Photo	EDS
	A	1444	. ND												
		644-4	ND				Pus	A 8	O/ambut		3-5	of dehas			
		F4-4	ND.				Pi	B 90	popo inha	<u> </u>	3-5	% debris	\		
		E4-4	ND							· .		-			
	. ·	4-4.	ND		·				13) : i/	31/12				
		134-4	W					•	/.	. /	/				
	B	64-4	ND				•						·		,
		F4-4	WD.												
		E4-4	ND												
	•		, .												

Page	4	of		٠	
1, 490	٠.	v	_		

Reservoirs Environmental, ino: TEM Asbestos Structure Count

	T
Laboratory name:	REI
1nstrument	JEOL 108 CX (N S
Voltage (KV)	100 KV
Magnification	20KX 10KX
Grid opening area (mm2)	0.01
Scale: 1L=	0.2S um
Scale: 10 =	0.05 6 um
Primary filter area (mrn2)	385
Secondary Filter Area (mm2)	
QA Type	

Client:	Rok
Sample Tyoe (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	898
Date received by lab	1/30/12.
Lab Job Number:	228714
Lab Sample Number:	857445

F-Factor Calculation (Indirect Preps Only):							
Fraction of primary filter used							
Total Resuspension Voluma (mi)							
Voluma Appliad to secondary filter (ml)							

Scope Alignment	Date Analyzed
Grid storage location	Month Analyzed
Counting mies (1SO, AHERA, ASTM)	AH.
Method (D=Direct, l=indirect, IA=Indirect, ashed)	7
Anatysis date	1/31/12
Analyzed by	JB

	Grid	Grid Opening	Structure	No. of St	mctures	Dimer	nsions	1dentification	Mineral Class				1 = y	es, blank	= no
L	<u></u>	Cita Operang	Туре	Primary	Total	Lenoth	Width		Amohibole	· c	NÀM	Sketch/Comments	Sketch	Photo	EDS
	A	K5-4	ND												
	•	175-4	ND.			Pu	<i>w</i>	600	The in fact		5%	debris.			
		(95-4	ND				1 Cm	3 90	% intent		5%	debnis			
Γ		63-3	NO									-			
F		F3-3	ND		•				.//	13	1/3	1/12			
	13	43-1	WD							1.		1			•
		(931	MD.				·								
Γ		F3.1	MD		·										
Γ	•	E3-1	M												

Reservoirs Environmental, Inc. TEM Asbestos Structure Count

Laboratory name:	REI
instrument	JEOL 100 CX /N S
Voltage (KV)	100 KV
Maanification	20KX 10KX
Grid opening area (mm2)	0.01
Scale: 1L≃	0.28 um
Scale: 1D=	0.056 um
Primary filter area (mrh2)	385
Secondary Filter Area (mm2)	
QA Tyoe	

. 1211 /3503(03 01)	acare count
Client:	RAR
Sample Type (A=Air, D=Dust):	A
Air volume (L) or dust area (cin2)	896
Date received by lab	1/30/12.
Lab Job Number;	228714
Lab Sample Number:	857446

F-Factor Calculation (indirect Pre	ps Only):
Fraction of primary filter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter (ml)	

	
Analyzed by	JB
Analysis date	1/3/12
Method (D=Direct, F=indirect, IA=Indirect, ashed)	7
Counting nites (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

	1		· · · ·		· · · · · ·			1	: :	`	I			
Grid	Grid Opening	Structure	No. of St	nictures	i⊃ime≀	nsions	Identification	Mineral Class				1 = y	es, biank	= no
		Туре	Primary	Total	Length	Width	•	Amohibole	· c	NÀM	Sketch/Comments	Sketch	Photo	EDS
A	63-3	ND					: •							
	F3-3	ND:			Pro		90% in	Em = 3	-5%	s de	ni 5			
; 	E3-3.	ND			Pn	B	10% of	ant 3-	5-2	odek	uS			
15	£3-3	ND			1			71			_			
. ' '	B3-3	N.D.					4	B 1/31/12		•				
B	K3-4	ND						/./						
	H3:4	ND										;		
	G3-4	WD.												
	F3-1	MD												. ;
				·						1 4				.00

Analytical Procedures - AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was employed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm² (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm² (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber: is a structure having a minimum length greater than or equal to 0.5

micron with an aspect ratio of 5:1 or greater with substantially parallel

sides.

Bundle: is a structure composed of three or more fibers in parallel arrangement,

with each fiber closer than the diameter of one fiber.

Cluster: is a structure with fibers in random arrangements such that all fibers are

intermixed and no single fiber is isolated from the group.

Matrix: is a fiber or fibers with one end free and the other end embedded or

hidden by a particulate. The exposed fiber end must meet the fiber

definition given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50th structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be unevenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm² clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

Area Analyzed, mm² = # GO counted x Average GO Area (mm)

Concentration, $s/cc = \frac{\text{\# Asbestos Structures}}{\text{\# GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area (mm}^2)}{\text{Average GO area (mm}^2)} \times \frac{\text{IL}}{\text{1000cc}}$

Filter loading, s/mm² = # Asbestos structures Area Analyzed (mm²)

GO = TEM grid opening



February 1, 2012

Laboratory Code: Subcontract Number:

RES NA

Laboratory Report: Project # / P.O. #

RES 228782-1 None Given

Project Description:

3rd West Sub - RMP

David Roskelley R & R Environmental 47 West 9000 South #2 Sandy UT 84070

Dear Customer,

Reservoirs Environmental, Inc. is an analytical laboratory accredited for the analysis of Industrial Hygiene and Environmental matrices by the National Voluntary Laboratory Accreditation Program (NVLAP), Lab Code 101896-0 for Transmission Electron Microscopy (TEM) and Polarized Light Microscopy (PLM) analysis and the American Industrial Hygiene Association (AIHA), Lab ID 101533 - Accreditation Certificate #480 for Phase Contrast Microscopy (PCM) analysis. This laboratory is currently proficient in both Proficiency Testing and PAT programs respectively.

Reservoirs Environmental, Inc. has analyzed the following samples for asbestos content as per your request. The analysis has been completed in general accordance with the appropriate methodology as stated in the attached analysis table. The results have been submitted to your office.

RES 228782-1 is the job number assigned to this study. This report is considered highly confidential and the sole property of the customer. Reservoirs Environmental, Inc. will not discuss any part of this study with personnel other than those of the client. The results described in this report only apply to the samples analyzed. This report must not be used to claim endorsement of products or analytical results by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without written approval from Reservoirs Environmental, Inc. Samples will be disposed of after sixty days unless longer storage is requested. If you have any questions about this report, please feel free to call 303-964-1986.

Sincerely.

Jeanne Spencer Orr

President

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE I. TEM AIR FILTER SAMPLE DATA AND ANALYTICAL RESULTS

RES Job Number:

RES 228782-1

Client:

R & R Environmental

Client Project Description:

Client Project Number / P.O.: None Given

Date Samples Received:

3rd West Sub - RMP

Analysis Type:

January 31, 2012

Turnaround:

TEM, AHERA

24 Hour

Date Samples Analyzed:

February 1, 2012

Client	Lab		Агеа	Air	Number of	Analytical	Asbestos	Filter
ID Number	ID Nur	nber	Analyzed	Volume	Asbestos	Sensitivity	Concentration	Loading
				Sampled	Structures			•
					Detected			
			(mm²)	(L)		(s/cc) [^]	(s/cc)	(s/mm²)
3W-013012 SW	EM	857996	0.0900	873	ND	0.0049	BAS	BAS
3W-013012 NW	EM	857997	0.0900	865	ND	0.0049	BAS	BAS
3W-013012 NE	EM	857998	0.0900	871	ND	0.0049	BAS	BAS
3W-013012 SE	EM	857999	0.0900	869	1	0.0049	0.0049	11.1

NA = Not Analyzed

ND = None Detected

BAS = Below Analytical Sensitivity

Average Grid Opening in mm² = 0.010

Filter Material = Mixed Cellulose Ester

Filter Diameter = 25 mm

Effective Filter Area = 385 sq mm

NVLAP Lab Code 101896-0; TDH: #30-0015

TABLE II. SUMMARY OF ANALYTICAL DATA

RES Job Number:

RES 228782-1

Client:

R & R Environmental

Client Project Number / P.O.: None Given

Client Project Description: 3rd West Sub - RMP Date Samples Received:

Analysis Type:

January 31, 2012

TEM, AHERA

Turnaround:

24 Hour

Date Samples Analyzed:

February 1, 2012

Client ID Number	Lab ID No	umber	Asbestos Mineral	Asbestos Structure Types*		Structures >5 Microns in Lengtb	**Excluded Structures	Asbestos Structures for		
			-	Fibers		Clusters		III Lengto		Concentration
3W-013012 SW	EM	857996	ND	0	0	0	0	0	0	0
3W-013012 NW	EM	857997	ND	0	0	0	0	0	. 0	0
3W-013012 NE	EM	857998	ND	0	0	0	. 0	0	0	0
3W-013012 SF	FM	857999	Chrysotile	1	0	0	0	0	0	1

^{*}See Analytical Procedure for definitions

^{**}C = Excluded from total due to lack of confirmation

^{**}L = Excluded from total for lengto less than 0.5 micron (AHERA only)

^{**}A = Excluded from total due to i ncorrect aspect ratio

ND = None Detected

Due Date: 24.12 Due Time:

Contact

Phone Email Fax

Date

REILAE RESERVOIRS ENVIRONMENTAI, INC... 6801 Logen St. Denver, CO 80216 · Ph: 303 984-1988 · Fex 303-477-4275 · Toll Free : 686 RESI-ENV

rage i ot r

INVOICE TO: (IF DIFFERENT) CONTACT INFORMATION: Contact Dave Roskeller Contact: Company: KFR Environmenta Company: Addrers: ddress: 47 W 90005 Fex: 14. 24070 Cet/pager ^{Cell/pager:} 801 541-1035 Project Numbor and/or P.O. #: dave menvino.com Project Descriptionn.ocstion: west Sub -RMP VALID MATRIX CODES ASBESTOS LABORATORY HOURS: Weekdays: 7am - 7pm REQUESTED ANALYSIS LAB NOTES: PLM / PCM / (TEM) RUSH (Same Day) PRIORITY (Next Day) ___STANDARD Bulk = B Air = A(Rush PCM = 2hr, TEM = 6hr.) Paint = P Dust = D CHEMISTRY LABORATORY HOURS: Weekdays: 8am - 5pm Soil = S Wipe = W RUSH 24 hr. 3-5 Day Metal(s) / Oust Swab = SW F = Food "Prior notification Is RCRA 8 / Metats & Welding g Drinking Water = DW | Waste Water = WW required for RUSH RUSH ___ 5 day ___10 day Fume Sean / TCLP O = Other turnarounda.** ŧ Organics 24 hr. ___ 3 day ___5 Day **ASTM E 1792 approved wipe media only** S S MICROBIOLOGY LABORATORY HOURS: Weekdays: 9am - 6pm E.call O157:H7, Coliforms, S.aureus ___ 24 hr. ___2 Day 3-5 Day 48 Hr. Salmonella, Listeria, E.coll, APC, Y & M Rush 24 Hr 48 Hr 3 Day 5 Day "Turneround times establish a laboratory pyfority, aubject to laberatory volume and are not guaranteed. Additional fee apply for aRerhours, weakends and holidoys." Matrix Code Special Instructions: EM Number (Laboratory METALS RCRA 8. Date Time Usa Only) Collected Collected Client sample ID number MICROBIOLOOY (Sample ID's must be unique) hh/mm a/o 110/17 3W-013017, SW 37 3W-013017 NW 38 Ce SW 013012 SF 8 9 10 (Additional samples shall be listed on attached long form.) Number of samples received: rmation received and will not be responsible for errors or amissions in calculatione resulting from the inaccuracy of original tiese. By signing dient/company representative agrees that submission of the following samples for requested analysis as indicated on this Cheig of Custody shall constitute an analytical services agreement with payment terms of NET 30 days, failure to comply with payment terms may result in a 1.5% monthly interest aurohange. Date/Time: 01/30/17 FedEx Relinguished By: Sample Condition: On Ice Sealed Intact Laboratory Use Only (Yes) No Temp. (F°) Yes / No Yes / No Received By: Date/Time: Results: Contact hone Email Fax Date Time Initials Contact Phono Email Fax Date Time Initials

> Contact Phone Email Fax 4: 7989 8358 5971 7-2011 version 1

Date

Time

Initials

Attachment I

Key to Count Sheets Count Sheets Analytical Procedures

Structures identifications consist of an Asbestos Type followed by a Structure Type

Asbestos Type

Structure Types

. A	=	Amosite	F =	Fiber
An	=	Anthophyllite	B =	Bundle
C	=	Chrysotile	C =	Cluster
Cr	=	Crocidolite	M =	Matrix
T	_	Tramolita		

ND = no structures detected

M = other structure associated with a matrix

NAM = Non Asbestos Mineral


XGB = partly obscured by a grid bar

Sizing Conversion
1 length unit = 5 mm on screen = 0.278 micron
1.80 length units = 0.5 micron
18.0 length units = 5 microns

1 width unit = 1 mm on screen = 0.0556 micron

TEM Analysts

Jeanne S. Orr Nathan DelHierro Angela Heitger Jonathan Bernard Paul D. LoScalzo Mark Steiner Norberto Zimbleman Robert Workman



Upper and lower 95% confidence bounds for the number of structures counted assuming a Poisson distribution.

Page	1.	of	

Reservoirs	Environmental, Inc.
TEM Asbes	tos Structure Count

Laboratory name:	REI
Instrument	JEOL 100 CX N S
Voltage fKV)	100 KV
Maanification	2010x 1010x
Grid opening area (rhm2)	0.01
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
OA Type	

RAK
A
873
1/31/12
27.8742
857996

Fraction of primary niter used	
Total Resuspension Volume (ml)	
Volume Applied to secondary filter	 -

Analyzed by	JB.
Analysis date	2-/1/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	D
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

ŀ	Grid	Grid Opening	Structure	No. of St	ructures	Dàne	nsions	Identification	Mineral Class				1 = y	es, blank	= no
	·	Grid Opening	Туре	Primary	Total	Length		identification	Amphibois	С	NAM	Sketch/Comments			EDS
	A	K4-4	ND							`					
		114-4	ND:			Pn	sA	8D	Lein by	7	ے ا	Lo de bus			
		644	ND.			Pn	o B	70	he in hu		5	Lo de bais			
		F4-4	ND		,	,,,,			6					, .	
	: 	E4-4.	ND						AB.	2/1/	12				
	3	K4-6	MD			·				1./1					
	·	H4-6	MD.				· · · · · · · · · · · · · · · · · · ·								
		64-6	2		-										
		F4-6	\$												
							1								

Page I. of	
------------	--

_ -	<u> </u>
Laboratory name:	REI
Instrument	JEOL 100 CX (N S
Voltage (KV)	100 KV
Magnification	2010x 1010X
Grid opening area (titm2)	0.01
Scale: 1L =	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	

Reservoirs Environmental, Inc. TEM Asbestos Structure Count

Client:	RAK
Sample Tyoe (A=Air, D=Dust);	A
Air volume (L) or dust area (crn2)	865
Date received by lab	1/3/12
Lab Job Number:	27.8742
Lab Sample Number	857197

F-Factor Calculation (Indirect Preps Only):

Freetign of primary litter used
Total Rasuspansion Volume (ml)
Volume Applied to secondary litter
(ml)

•			a
2		•	G
7			s
·.	_		
	, ·		

Analyzed by	JB.
Analysis date	2-/1/1L
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	15
Counting mies (ISO, AHERA, ASTM)	- AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Grid	Grid Opening	Structure	No. of St	ructures	Dime	nsions	Identification	Mineral Class	• •			1 = y	es, blank	= no ·
		Туро	Primary	Total	Length	Width		Amphibole	C	NAM	Sketch/Comments	Sketch.	Photo	EDS
A	133	ND												
	K3-3	ND.			2	, A.C	H3.	2.80 % in	rut	5	-10% dol	ns		
•	H3-3.	M).						1. It	P					
	63-3	M						///5	2	/1/12	,			
	F3-3	ND							/	/				<u>.</u>
3	F2-6	·WO												· .
	EZ-6	MD.												·
	(2-6	07												
	133-1	NO				:								
· .						13,71						·		

Page	1. of	
raue	1. 01	

Reservoirs Environmental, Inc. TEM Asbestos Structure Count

Laboratory name:	REI .
Instrument	JEOL 100 CX N S
Voltage (KV)	100 KV
Magnification	2010x 1010x
Grid opening area (rhm2)	0.01
Scale: 1L=	0.28 um
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
QA Tyoe	

Client:	RAR
 Samole Type (A=Air, D=Dust):	A :
Air volume (L) or dust area (cm2)	871
Data received by lab	1/31/12
Lab Job Number.	27.8742
Lab Sample Number.	857198

F-Factor Calculation (Indirect Pre	ps	Only):	
Fraction of primary litter used			
Total Resuspension Volume (mi)			
Volume Applied to secondary filter (ml)	-	·	

-	
Analyzed by	JB.
Analysis date	2/1/12
Method (D=Direct, I=Indirect, IA=Indirect, ashed)	
Counting rules (ISO, AHERA, ASTM)	AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

	Grid	Grid Opening	Structure	No. of St	uctures	Dimer	nsions	1dentification	Mineral Class				1 = y	es, blank	= no
			Type	Primary	Total	Length	Width	• • • • • • • • • • • • • • • • • • • •	Amohibole	C	NAM	Sketch/Comments	Sketch	Photo	EDS
	A	14-1	ND							•					
		K4-1	MD				2	4	of nhu	4	Į,	10hodel	715		
· ":	٠.	H4-1	MD			Pins	7	70	0/1/		<u>(</u> -	o % debut	J		
• :		G4-1	WD.			1			6				·		·
		F4-1.	M					11	2/1/12						
طال مارام	CB	6.3-1	ND.					17	1/;						
44		F3-1	2					/							
•		E3-1	NO.												
		67-4	ND												
•															

•			
Becomedia	E-141		
Reservoirs	⊏11AltoUI	mentai	, INC.
			•
TEM Asbes	ne Stru	~fiira €	'Allat
I FIM WARES	ios ou ui	fare f	June

	<u> </u>
Laboratory name:	REI .
1nstrument	JEOL 100 CX N S
Voltage (KV)	100 KV
Magnification	2010x 1010x
Grid opening area (mm2)	0.01
Scale: 1L=	0.28 lim
Scale: 1D =	0.056 um
Primary filter area (mm2)	385
Secondary Filter Area (mm2)	
CA Tune	

Client:	<u></u>
Sample Tyoe (A=Air, D=Dust):	A
Air volume (L) or dust area (cm2)	869
Date received by lab	1/31/12
Lab Job Numbor.	27.8742
Lab Sample humber	857199

Lab Cample Hamber.	, ,,	371	7	
F-Factor Calculation (Indirect Pr	ene (Inlui-	ι.	
F-Factor Calculation (mullect Fi	eh2 (July).		
Fraction of polmary filter used				
Total Resuspension Volume (ml)	1			
Volume Applied to secondary filter	1	•, •	٠,	

	·
Analyzed by	JB.
Analysis date	2/1/12
Method (D=Direct, l=Indirect, IA=Indirect, ashed)	
Counting rules (ISO, AHERA, ASTM)	·AH
Grid storage location	Month Analyzed
Scope Alignment	Date Analyzed

Qrid	Grid Opening	Structure Type	No. of St	ructures	ctures Dimensions		Identification	Mineral Class			1 = yes, blank = no			
			Primary	Total	Length Width	Amohiboie		c	· NAM	Sketch/Comments	Sketch.	Photo	EDS	
A	14-4	ND.												
	K4-4	ND.			: (+	has	A. 8	Ope infin	1	5-	10 / de la			
	144-4	M			7	D'	3 6	6 hinhard	<u> </u>	5-	10 % debu		,	
	H3-1	ND			,								•	
	63-1:	w		•										
B	F2-4	F		1	3	1	CD.		·V		\			
	C2-4	MD.						· shi						
	C4-4	MO						2/32	1/12					
-	134-4.	M					·	/1/:	·					
								/						٠.

Analytical Procedures - AHERA

Transmission electron microscopy/energy dispersive X-ray spectrometry/selected area electron diffraction (TEM/EDX/SAED) was employed in the analysis of the samples, which were collected on 25 mm mixed cellulose ester air filters. A portion of each filter was collapsed with acetone and etched in a plasma asher. The etched filter was then coated with a thin layer of carbon in a carbon side down. The sample was then placed inside a condensation washer and treated with acetone to remove the filter matrix and expose any inert material.

For each sample, enough grid openings on a 200 mesh TEM grid are analyzed to ensure an analytical sensitivity of at least 0.005 structures/cc. A minimum of four grid openings from two preparations are analyzed for each sample. The grid openings are searched for fibrous structures which, if present are analyzed by SAED and/or EDX (elemental analysis). The AHERA protocol requires SAED confirmation of enough chrysotile asbestos structures on each sample to cause the sample to exceed 70 structures/mm² (usually 4 or 5 structures). Both SAED and EDX confirmation are required of enough amphibole structures on each sample to cause the sample to exceed 70 structures/mm² (usually 4 or 5 structures) per sample. Either SAED or EDX is required for the remaining asbestos structures of either type. The morphology of each structure is determined and the length and the diameter of any asbestos structures are recorded. Asbestos fibers, bundles, cluster and matrices were identified and recorded. The asbestos structures have been defined in AHERA as follows:

Fiber: is a structure having a minimum length greater than or equal to 0.5

micron with an aspect ratio of 5:1 or greater with substantially parallel

sides.

Bundle: is a structure composed of three or more fibers in parallel arrangement,

with each fiber closer than the diameter of one fiber.

Cluster: is a structure with fibers in random arrangements such that all fibers are

intermixed and no single fiber is isolated from the group.

Matrix: is a fiber or fibers with one end free and the other end embedded or

hidden by a particulate. The exposed fiber end must meet the fiber

definition given above.

If more than 50 asbestos structures are identified and confirmed on a sample, AHERA analysis may be terminated after completion of the grid opening, which contains the 50th structure. AHERA protocol requires the laboratory to reject any clearance sample which contains in excess of 25% total particulate loading or which appears to be unevenly loaded.

The AHERA protocol includes specific sampling requirements, including minimum numbers of samples and minimum air volumes. Specifically, the 70 structures/mm² clearance criteria is only allowed for sets five inside samples (collected in a group of 13 samples including: five outsides and three blanks) with volumes greater than 1200 liters (40 CFR Part 763, page 41894). Deviation from the AHERA sampling protocol may affect the validity of the analytical results. Analysis of samples collected by non-protocol methods are not accredited by NVLAP

Equations Used for Calculations

Area Analyzed, mm² = # GO counted x Average GO Area (mm)

Concentration, $s/cc = \frac{\text{\# Asbestos Structures}}{\text{\# GO Counted}} \times \frac{1}{\text{Volume (L)}} \times \frac{\text{Eff. Filter Area (mm}^2)}{\text{Average GO area (mm}^2)} \times \frac{1L}{1000cc}$

Filter loading, s/mm² = # Asbestos structures Area Analyzed (mm²)

GO = TEM grid opening